

SCALE:  
NTS

**NOTE:** ALL VALVES, LEADS AND FITTINGS SHALL BE WRAPPED WITH 8 MIL. POLY TO GROUND LEAD


**APPROVED FIRE HYDRANT**  
**MUELLER IMPROVED CENTURIAN**  
**#A - 423 AND**  
**AMERICAN AVK**

**WATER MAIN TEE**  
1. USE M.J. x M.J.  
FOR LESS THAN 12"  
2. USE M.J. x FLG.  
FOR 12" OR LARGER



City of  
Horseshoe Bay

**FIRE HYDRANT**  
**STANDARD DETAIL**  
NTS



*Willis Environmental*  
*Engineering, Inc.*

CONSULTING ENGINEERS

310 MAIN STREET, MARBLE FALLS, TEXAS 78654

• (830) 693-3566 • FAX (830) 693-5362 • e-mail: tplumlee@willis-engineering.com